



JOHN W. HICKENLOOPER
MAYOR

CITY AND COUNTY OF DENVER

DEPARTMENT OF SAFETY
Denver FIRE DEPARTMENT

FIRE PREVENTION BUREAU
201 WEST COLFAX AVENUE
DENVER, COLORADO 80202
V: (720) 865-2720
F: (720) 865-2880

Mr. Brent Mlika
Fike Corporation
704 South 10th St.
PO Box 610
Blue Springs, MO 64013

Rev: 10 October 2005
Date: 21 January 2005

Dear Sir,

Subject: Fire Alarm Panel Review

Panel: **Cybercat Fire Alarm Control Panel** _____, is **APPROVED** for use in Denver subject to the conditions below. **Your acknowledgment of these conditions and issuance of an appropriate service bulletin to suppliers and installers is required prior to posting this panel on our approved FACP website.** Refer to www.denvergov.org site for approved panel listing. It is a condition of approval that panels are listed for use with all connected devices.

Panel: _____, is **DISAPPROVED**. See below.

- ___ Class 1 panels are for fire alarm use only; combined fire/security/access control systems are not allowed.
- ___ Panels that require a key or password to reset are not allowed.
- XX** Panels that have programmed keys or switches for Initiating or notification device or zone disable are not allowed. **Zone and/or device disable functions shall be password protected.**
- XX** Panels with only LCD annunciators are not allowed. On-board or remote directory LED or graphic annunciation is required. **Zone annunciator 10-2373 is not acceptable. Use of 10-11x Graphic Annunciator is required.**
- ___ Panels with programmed key or switch for city disconnect are not allowed.
- ___ Panels without a secured access to system reset, alarm silence and acknowledge keys are not allowed.
- ___ Panels without a listing from an approved testing laboratory are not allowed. Panels shall be listed for the type of system ((L) local, (R) remote, (P) proprietary, (C) central station) and service ((A) automatic, (M) manual, (SS) sprinkler supervisory, (WF) water flow) per UL. Panels for releasing service shall be so designated in the listing.
- ___ Panels shall have separate audible and visual indications for alarm, trouble and supervisory indications. Alarm indicators shall be red, trouble and supervisory indicators shall be yellow.
- XX** Other: **IR communication shall be disabled for normal operation. Supplemental power supply model 10-2474 shall be provided with a supervised fan per UL. Alarm devices with remote LED's shall be limited to 30 such devices on a single loop.**

You may request an appointment to demonstrate your panel by contacting 720.865.2962.