

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner  
MEA 18-01-E

Report of Material and Equipment Acceptance Division

Manufacturer - Fike Corporation, 704 South 10<sup>th</sup> Street, Blue Springs, Missouri 64013.

Trade Name - Fike.

Product - Enclosure for Fire Control System.

Pertinent Code Sections - Subchapter 17 and Reference Standard RS 17-3 thru 17-3c.

Tests - UL 864.

Laboratory - Underwriters Laboratories Inc.

Test Reports - File S2203, Project 95NK26185 dated March 12, 1996 and revised March 27, 1998 and UL letter dated January 17, 2001.

Description - The two and three bay enclosure assemblies are designed to house either the Fike Cheetah Control Panel or the Fike single Hazard (SHP) Control Panel. Previously, each of these control panels had its own separate enclosure.

Model Number	Description
10-055-2-R	Red Two Bay Enclosure
10-055-3-R	Red Three Bay Enclosure

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections to Letter dated February 16, 2001, F.P. Index No. 0101057.

Recommendations - That the above enclosures be accepted on conditions that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and with Reference Standard RS 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard and on further condition that:

1. Only the enclosures that are painted red are acceptable. Models #10-055-2 R and 10-05503 R shall be used to house Fike's Cheetah control panel or the Single Hazard panel (SHP).

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in section 27-131 of the Building Code.

Final Acceptance \_\_\_\_\_

Examined by \_\_\_\_\_

