



NOTICE OF AUTHORIZATION TO APPLY THE UL MARK

2008-04-10

Mr. Brent Mlika
Fike Corp
704 S 10th St Po Box 610
Blue Springs, MO 64015
United States

Fax number: 816-229-5082
E-mail: brent.mlika@fike.com

Reference: File S3217 Project 07NK11698 P.O. Number 87041
Product: USL - Fire Alarm Equipment: Multi-Interface Module: Model 10-2583 & 10-069; Ethernet
Module, Model 10-2627 & 10-074

Dear Mr. Mlika,

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

UL's investigation of your product has been completed under the above project number and the subject product was determined to comply with the applicable requirements.

This letter temporarily supplements the UL Follow-Up Services Procedure and serves as authorization to apply the UL Listing Mark only at the factory under UL's Follow-Up Service Program to the subject product, which is constructed as described below:

Identical to the subject model, which was submitted to UL for this investigation. The UL Records covering the product will be in the Follow-Up Services Procedure, File S3217, Volume 8.

To provide the manufacturer with the intended authorization to use the UL Mark, the addressee must send a copy of this Notice and all attached material to each manufacturing location as currently authorized in File S3217, Volume 8.

This authorization is effective from the date of this Notice and only for products at the indicated manufacturing locations. Records in the Follow-Up Services Procedure covering the product are now being prepared and will be sent to the indicated manufacturing locations in the near future. Please note that Follow-Up Services Procedures are sent to the manufacturers only unless the Applicant specifically requests this document.

Products that bear the UL Mark shall be identical to those that were evaluated by UL and found to comply with UL's requirements. If changes in construction are discovered, appropriate action will be taken for products not in conformance with UL's requirements and continued use of the UL Mark may be withdrawn.

Sincerely,

Henry Lee
Project Engineer
Department: 3017HNBK
Tel: 847-664-1564
Fax: 847-407-1564
E-mail: henry.f.lee@us.ul.com

Reviewed by:

David Stone
Staff Engineer
Department: 3017CNBK
E-mail: david.j.stone@us.ul.com



California State Fire Marshal (CSFM) Listing Certification Letter

Testing Laboratory:

Underwriters Laboratories Inc
333 Pfingsten Rd
Northbrook, IL 60062 USA

Test Report Date: 2008-02-20

File, Project Number: S3217, 07NK11698

Manufacture:

Fike Corp
704 S 10th St Po Box 610
Blue Springs, MO 64015
U.S.A

Project Handler:

Henry Lee, 847-664-1564

Reviewer:

David Stone, 847-664-3387

Product Description:

Control Unit Accessory Multi-Interface Module, Model 10-2583 & 10-069. The Multi-Interface Module is used to connect the Cheetah to Cheetah Xi and CyberCat 254/1016. Also used as a printer interface between Fike listed panels and the Keltron Printer (90-Series) or Parallel Printer that is Listed for fire protected signaling use.

Control Unit Accessory Ethernet Module, Model 10-2627 & 10-074. The Ethernet Module is ancillary device that provides networking between Panel Cheetah Xi, CyberCat 1016, -254 and Panel Cheetah Xi 50 and CyberCat 50.

Electrical Rating:

Model	Rating
10-2583 and 10-069	24 V Nominal; 15-30 Vdc rated voltage 1.2 A maximum current; 110 ohms maximum line resistance 0.05µF maximum line capacitance; Max. wire length up to 4000 feet Supervised, Power limited
10-2627 and 10-074	24 V Nominal; 15-30 Vdc rated voltage 134 mA maximum current; 110 ohms maximum line resistance 0.05µF maximum line capacitance; Max. wire length up to 4000 feet Supervised, Power limited

Applicable Standards evaluated to:

The products described herein have been investigated to, and found in compliance with, the Standard for Control Units and Accessories for Fire Alarm Systems, Ninth Edition of UL 864, with revisions dated May 29, 2007.