

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0900:0155 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Fike Protection Systems 704 South 10th St., Blue Springs, MO 64024
Contact: Brent Mlika (816) 229-3405 Ext: 1220 Fax (816) 229-5082
Email: brent.mlika@fike.com

DESIGN: Models 10-2698, 10-2699 ARM III Disconnect Switches and 10-2075, 10-2076 Solenoid Disconnect Switches. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 15-30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as control unit accessories or use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

05-07-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division