

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-2010:0502

Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: FIKE CORPORATION 704 South 10th Street, P.O.Box 610, Blue Springs, MO 64013
Contact: Brent Mlika (816) 229-3405 Ext: 1220 Fax (816) 229-5082
Email: brent.mlika@fike.com

DESIGN: Models 10-2963 Manual Release, 10-2965 System Abort, 10-2967 Main/Reserve, 10-2969 System Input, 10-2973 System Input, 10-2975 Manual Release and System Abort, and 10-2977 Countdown Timer, Manual Release, and Abort. The Model 10-2975 Manual Release and Abort assembly consists of the Model 10-2963 Manual Release switch and the Model 10-2965 Abort Switch. The Model 10-2977 countdown timer switch consists of the Model 10-2963 Manual Release switch, Model 10-2965 Abort Switch, and 10-1389A timer assemblies. The countdown timer is intended to operate as a remote indication of the time remaining until agent release. The time programmed on the timer does not control the time available for release, this function is accomplished by the control unit.

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 30 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed compatible fire alarm control units. Intended installation environment Indoor, dry. Refer to listee's Installation Instruction Manual for details.

10-04-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **October 08, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division