


ODORIZER



Description

The Odorizer is used to inject a small amount of wintergreen scent into the agent as it flows through the piping network, discharging into the hazard area carrying a scent of wintergreen.

The purpose of the wintergreen scent is to warn personnel that the area contains a concentration of suppression agent and precautions must be taken, by either leaving the area immediately or securing proper breathing apparatus.

The internal ampoule containing the oil of wintergreen must be replaced and the broken glass in the device must be cleaned out after each system discharge. It is recommended to use 1 odorizer per 20 cylinders.

Specifications

| | |
|-------------------------|-----------------|
| Part Number | IG71-240 |
| Rebuild Kit Part Number | IG71-241 |
| Thread Size & Type | 3/4" NPT (Male) |
| Material | Brass (Body) |

Approvals

Underwriters Laboratories (UL)
 Underwriters Laboratories of Canada (ULC)
 Factory Mutual (FM)

For exact certification listings, please reference the respective agency web site.

This document is only intended to be a guideline and is not applicable to all situations. Information is subject to Fike's full disclaimer at <http://www.fike.com/disclaimer>.