

PROINERT^{®2} INSTRUCTIONAL SIGNS

DESCRIPTION

Caution / Advisory Signs are provided to comply with NFPA 2001 requirements, and to provide the necessary information to personnel in the area.

The signs are made from flame retardant, Lexan polycarbonate material. Each sign has an adhesive backing for mounting purposes. The caution lettering and backgrounds meet the requirements of ANSI Z535.

Listings and Approvals

UL / ULC Listed & FM Approved

CAUTION "EXIT" SIGN (P/N 02-11776)

This sign is provided to alert personnel that the room is protected by a Prolnert system and to evacuate the area when the alarms sound.

- Overall Size: 14.0" x 7.8" x 0.10"
(355.6 mm x 198 mm x 2.54 mm)
- Lettering Size: 1½" – Caution
3/8" – Text
- Color: White – Sign
Black – Caution & Text lettering
Yellow – Caution Background



This Sign should be placed on the inside of each exit door and next to or under an audible/visual alarm inside the protected space.

CAUTION "DO NOT ENTER" SIGN (P/N 02-11777)

This sign is provided to alert personnel that the room is protected by a Prolnert system and that they should not enter the area when the alarm sounds or during or after discharge.

- Overall Size: 14.0" x 7.8" x 0.10"
(355.6 mm x 198 mm x 2.54 mm)
- Lettering Size: 1½" – Caution
3/8" – Text
- Color: White – Sign
Black – Caution & Text lettering
Yellow – Caution Background



This sign should be placed adjacent to each audible/visual device outside the protected space and on each entrance door to notify personnel that the Prolnert system has discharged.

SYSTEM "RELEASE" SIGN (P/N 02-11778)

This sign is provided to identify each Manual Release Station associated with the Prolnert system as the place where the Prolnert system can be manually discharged. This reduces the risk of a Manual Discharge Station being mistaken for a Fire Alarm Pull Station.

- Overall Size: 4.0" x 2.25" x 0.10"
(101.6 mm x 57.2 mm x 2.54 mm)
- Lettering Size: 1/4" – Text
- Color: White – Sign / Red – Text lettering



